



**HELLENIC GAS  
TRANSMISSION  
SYSTEM OPERATOR**

357-359, MESSOGION AVE.,  
15231 ATHENS, GREECE  
Tel.: 210 6501258  
Fax : 210 6501551

**TECHNICAL JOB  
SPECIFICATION**

**629/1**

**REVISION 0**

**DATE 05-04-2011**

# **HIGH PRESSURE (HP) TRANSMISSION SYSTEMS**

## **GAS SLAM- SHUT VALVES**

*This document is the property of DESFA SA and it shall not be reproduced, copied or used for any purpose other than that for which it is specially furnished*

Job Spec. No 629/1  
 Revision 0  
 Date 05-04-2011  
 Page 2 of 8

**QUALITY ASSURANCE PAGE**
**CHANGES LOG**
**REVISIONS LOG**

0	05-04-2011	FIRST ISSUE	PQ DPT.	VG
Rev. No	Rev. Date	REASON FOR CHANGE	Made By	Approved By

**Job Spec. No** 629/1  
**Revision** 0  
**Date** 05-04-2011  
**Page** 3 of 8

**CONTENTS**

- 1.0 SCOPE**
- 2.0 GENERAL REQUIREMENTS**
- 3.0 INSPECTION AND CERTIFICATION**
- 4.0 COMPLIANCE WITH THE EU DIRECTIVES**

**Job Spec. No** 629/1  
**Revision** 0  
**Date** 05-04-2011  
**Page** 4 of 8

**REFERENCED DOCUMENTS**

Job Specification 500/5  
[Piping Material]

Job Specification 830/1  
[External Painting]

Job Specification 970/2  
[Shop Inspection of Equipment and Materials for NGT Project]

EU DIRECTIVE 94/9/EC ATEX  
[Equipment Explosive Atmospheres Directive]

EU DIRECTIVE 97/23/EC PED  
[Pressure Equipment Directive]

EU DIRECTIVE 2006/95/EC LVD  
[Low Voltage Directive]

ELOT EN 14382  
[Safety devices for gas pressure regulating stations and installations - Gas safety shut-off devices for inlet pressures up to 100 bar]

ELOT EN 60529  
[Degrees of protection provided by enclosures (IP code)]

ELOT EN 60947-5-6  
[Low-voltage switchgear and control gear - Part 5-6: Control circuit devices and switching elements, DC interface for proximity sensors and switching amplifiers (NAMUR)]

ELOT EN ISO 8434  
[Metallic tube connections for fluid power and general use]

DIN 2353  
[Non-soldering compression fittings with cutting ring - Complete fittings and survey]

**1.0** **SCOPE****1.1** **ITEM**

Slam-shut valves (safety shut-off devices).

**1.2** **SERVICE**

Non corrosive gas.

**1.3** **APPLICATION**

Provide rapid shut-off of gas supply in the event where the pressure in the down stream piping system has reached an upper or lower set pressure.

**2.0** **GENERAL REQUIREMENTS****2.1** **LEGISLATION AND STANDARDS**

- EU DIRECTIVE 97/23/EC PED
- EU DIRECTIVE 94/9/EC ATEX
- EU DIRECTIVE 2006/95/EC LVD
- ELOT EN 14382

**2.2** **UNITS**  
Metric**2.3** **PATTERN**

Manufacturer's standard.

Valve body shall be provided with indication of flow direction.

**2.4** **CONSTRUCTION****2.4.1** **GENERAL**

The slam-shut valve shall be gas operated, but may only consume gas momentarily when triggered. They shall be pilot operated.

All pressure safety valves shall offer protection facilities against unauthorized adjustments of the set-points.

In normal operation as well as in case of a diaphragm break-down, gas may not enter the room in which the valve is installed.

**2.4.2 RESPONSE TIME**

Less than two seconds.

**2.4.3 ACCURACY**

As per ELOT EN 14382.

**2.4.4 VALVE BODY DESIGN**

Split body or top-entry design.

The slam-shut valve consists of a valve body, an actuator, a controller, a proximity sensor and other items necessary to provide a safe function. The design of the valve body shall facilitate easy maintenance preferably without the need to remove the entire valve from the pipeline.

**2.4.5 FLANGES**

Flanges shall conform to the relevant piping specifications (**Job Specification 500/5**).

**2.4.6 SEAT SEALING**

Soft seated or metal-to-metal with resilient inserts.

**2.4.7 ACTUATOR CONTROLLER BODY OR ANY EXTERNAL CONNECTION**

Shall be designed for at least the same pressure rating as the valve body.

**2.4.8 CONTROLLER**

The controller shall have provision against unauthorized changes of set point.

**2.4.9 AUXILIARY PIPING AND CONNECTIONS**

Means of pressure equalizing shall be provided as an integral part of the slam-shut valve.

Auxiliary piping and fittings shall be made of stainless steel.

Fittings shall conform to **DIN 2353** and **ELOT EN ISO 8434**.

If the specified fittings are not supplied, adaptor fittings shall be delivered.

**2.4.10 ADDITIONAL TRIGGERING DEVICE**

Local, manually operated.

Mounting of remote controlled triggering device shall be possible.

**2.4.11 POSITION INDICATION**

Local indication of open and closed position.

**2.4.12 ACCESSORIES**

The valve shall be supplied with non "contact" inductive proximity sensor for close signaling.

The proximity sensor shall be in accordance with **ELOT EN 60947-5-6**. Enclosure protection shall be min. IP 65 (**ELOT EN 60529**), as far as outdoor installations are concerned. For indoor installations, IP 54 protection class can be accepted. The proximity switch shall be suitable for use in a hazardous area, and in accordance with its classification study. The applicable norm shall be the **EU Directive 94/9/EC ATEX**.

Impulse lines of SSV must be provided with 3-way spring actuated valve to allow on stream verification/adjustment. The outdoor installed impulse lines shall be electrically heat traced and insulated to maintain a gas temperature of at least +5° C, when the ambient temperature drops to -20° C.

**2.5 MATERIALS**

**2.5.1 GENERAL**

Only materials conforming to recognized material standards shall be used.

Attention is drawn to **Job Specification 970/2**, where the material certification requirements are specified.

**2.5.2 VALVE BODY**

Cast or forged steel as given in **ELOT EN 14382**.

**2.5.3 ACTUATOR AND CONTROLLER**

The materials that shall be used for all moving parts and sliding surfaces which are vital to the trouble-free functioning of the safety device shall be corrosion - resistant.

**2.5.4 SOFT SEATS AND SEALS**

Suitable elastomer.

**2.6 SURFACE TREATMENT**

Refer to **Job Specification 830/1**.

**2.7 NON DESTRUCTIVE EXAMINATION**

**2.7.1 BODY**

All exterior and accessible interior surfaces of bodies and covers shall be magnetic particle examined according to **ELOT EN 14382**.

**2.7.2 WELDS (IF ANY)**

All joints shall be radiographed and found acceptable in accordance with **ELOT EN 14382**.

Where both radiography and ultrasonic examinations are unfit for detection then magnetic particle examination may be used.

**2.8 TYPE TEST**

In accordance with **ELOT EN 14382**.

**2.9 FACTORY TEST**

Each slam-shut valve shall be tested in accordance with the requirements of **ELOT EN 14382**.

**2.9.1 STRENGTH TEST**

As per **ELOT EN 14382**.

**2.9.2 TIGHTNESS TEST**

As per **ELOT EN 14382**.

**2.9.3 FUNCTIONAL TEST**

Each valve including accessories shall pass a functional test for accuracy group, response time verification, etc, as per **ELOT EN 14382**.

**2.10 MARKING**

Each safety valve shall be fitted with a stainless steel marker plate, indicating all relevant technical data required by **ELOT EN 14382**.

The plate shall additionally be marked with the contract and item tag numbers.

**2.11 DELIVERY**

The slam-shut valves shall be delivered completely assembled. All outlets shall be capped and protected against corrosion.

**3.0 INSPECTION AND CERTIFICATION**

Inspection will be performed by an Accredited Inspection Body appointed by Owner.

Inspection requirements are defined in the following documents.

- a. Material Requisition.
- b. **Job Specification 970/2**.
- c. Relevant project specifications.
- d. Inspection clauses of applicable codes.

Inspection procedures to be followed are detailed in Owner document "Inspections and Test Instructions for NGT Project".

**4.0 COMPLIANCE WITH THE EU DIRECTIVES**

All parts that comply with the "New Approach" directives shall be provided with:

- a. A physical CE marking and other information as required by the relevant directives.
- b. A declaration of conformity which lists all the directives with which the product complies.
- c. Any other information specified by the directive, e.g. user instructions.